

Certificate

Certified Passive House component

for cool, temperate climate, valid until 31.12.2014

Category: Window Frame
Manufacturer: SLAVONA, s.r.o.

378 81 Slavonice, CZECH REP.

Product name: Progression

The following comfort criteria were used in awarding this certificate:

Given a Ug value of 0.70 W/(m²K) and a window size of 1.23 m by 1.48 m,

 $U_{W} = 0.80 \quad W/(m^{2}K) \leq 0.80 \, W/(m^{2}K)$

Taking into account the installation based thermal bridges, and provided that the installation is, with regard to the thermal bridges, equal or better than shown in the data sheet, the window meets the following criterion.

 $U_{\text{W,installed}} \leq 0.85 \text{ W/(m}^2\text{K)}$


Thermal data

	U _f -value [W/(m ² K)]	Width [mm]	Ψ _g [W/(mK)]	f _{Rsi=0.25}
Spacer			SwisspacerV*	
Bottom	0.81	109	0.026	0.72
Side/top	0.83	89	0.025	0.72

*Spacers of lower thermal quality, especially those made of aluminium, lead to significantly higher thermal losses and lower temperature factors.

Further information see data sheet

Passive House Institute Dr. Wolfgang Feist 64283 Darmstadt GERMANY



not suitable for Passive

Houses

phC certifiable component






Data Sheet SLAVONA, s.r.o., Progression

Manufacturer SLAVONA, s.r.o.

Stálkovská 258, 378 81 Slavonice, CZECH REPUBLIC

Tel.: +420 384 493 400, +420 604 271 549

Email: zora@slavona.cz, libor.kamir@slavona.cz, www.slavona.cz




Description

Timber frame (Spruce and Thermowood) with insulation ($\lambda = 0.058 \text{W/mK}$). Used Pane: 48 mm (4/18/4/18/4), intersection of the Glass: 18 mm.

Thermal data for the window frame

	U _f -value	Width	Ψ_{g}	f _{Rsi=0.25}
	$[W/(m^2K)]$	[mm]	[W/(mK)]	[-]
Spacer			SwisspacerV*	
Bottom	0.81	109	0.026	0.72
Side/top	0.83	89	0.025	0.72
Mullion	0.82	164	0.026	0.72




^{*} Spacers of lower thermal quality leading to higher thermal losses and lower temperatures.



Data Sheet SLAVONA, s.r.o., Progression

Installation



Installation based thermal bridge $\Psi_{\text{instal.}}$ in Passive House suitable walls

Position		EIFS	Timber construction wall	Ventilated facing
Bottom	[W/(mK)]	0.010	0.020	0.008
Side/top	[W/(mK)]	-0.005	0.014	0.000
U _{W,instal.}	[W/(m ² K)]	0.79	0.84	0.80

Explanatory notes

The window U-values were calculated based on a 1.23 m by 1.48 m window $U_g = 0.70 \text{ W/(m}^2\text{K})$. If better glazing is used, the window U-value decrease as follow:

U Glazing	$\mathbf{U_g}$ [W/(m ² K)]	0.66	0.60	0.54
U Window	$\mathbf{U}_{\mathbf{W}} \left[\mathbf{W}/(\mathbf{m}^2 \mathbf{K}) \right]$	0.77	0.72	0.68

Depending on the thermal losses through opaque elements, transparent components are categorised according to efficency classes. These thermal losses include the losses through the frame, multiplied by its width, the thermal bridge at the edge bond as well as the length of the edge bond.

Please ask the manufacturer for a detailed report containing all calculations and results.

For further information, please visit www.passivehouse.com or www.passipedia.org.